

LOCATE STORM SEWER MANHOLES
IN CENTER OF TRAFFIC LANE

LOCATE SANITARY SEWER
MANHOLES IN CENTER OF
STREET.

STUB-OUT FOR FUTURE EXTENSIONS
SHALL EXTEND BEYOND THE
INTERSECTION RADIUS OR
40' MINIMUM FROM VALVE.

FIRE HYDRANT WITH
VALVE AND BOX

R.O.W.

EDGE OF ASPHALT

40' MIN.

6'
MIN.

10'
MIN.

8'

10'
MIN.

SANITARY SEWER @ CL

PIPE PLUG &
THRUST BLOCK

STORM SEWER

6'
MIN.

EDGE OF ASPHALT

VALVE AND BOX
(ALT. LOC.)

TYPICAL UTILITY PLAN FOR STREETS



CLIFTON SANITATION
DISTRICT

GENERAL UTILITY
DETAIL

APPROVED: DN
DATE: FEB. 2006
DRAWN: CM

PAGE
GU-01